


EQUIPOS INVERTER INDIVIDUALES CON ELEMENTO RADIANTE HASTA 32Z



①	AZDI6ACUAZONE	Central de sistema Airzone Acuazone 32Z
②	AZDI6BLUEFACEC[B/N]	Tto. cable a color Airzone Blueface 32Z [blanco/negro]
③	AZDI6THINKC[B/N]	Tto. cable monocromo Airzone Think 32Z [blanco/negro]
④	AZDI6THINKR[B/N]	Tto. radio monocromo Airzone Think 32Z [blanco/negro]
⑤	AZDI6MC[XXX]C	Módulo de zona cable Airzone ud. individual [marca] 32Z
⑥	AZDI6MZZONC	Módulo de zona motor Airzone cable 32Z
⑦	AZDI6ZMO[XXX]R	Módulo de zona radio Airzone ud. individual [marca] 32Z
⑧	AZDI6MCFRR	Módulo de zona radio Airzone ud. individual infrarrojos 32Z
⑨	AZDI6OUTPUT8	Módulo de control elementos radiantes Airzone 32Z
⑩	AZX6WEBSCLLOUDC	Webserver Airzone Cloud Ethernet

Lógica Funcionamiento Relé "Activación elemento radiante" _ Sistema Distribuido:


ESTADO / MODO	STOP	VENTILACIÓN	FRÍO (AIRE)	FRÍO (RADIANTE)	CALOR (AIRE)	CALOR (RADIANTE)
DEMANDA ON	CALD. OFF	CALD. OFF	CALD. OFF	CALD. ON	CALD. OFF	CALD. ON
DEMANDA OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF

— Cable Bus Airzone
⊗ Elemento con alimentación eléctrica independiente

Para mayor información técnica pulse [aquí](#)

Nota importante: Los presentes planos sirven de base para la realización del proyecto de ejecución

INDIVIDUAL INVERTER UNITS WITH RADIANT HEATING-UP TO 32Z



①	AZDI6ACUAZONE	Airzone Acuazone main control board 32z
②	AZDI6BLUEFACEC[B/N]	Airzone Blueface color Thermostat wired 32Z [white/black]
③	AZDI6THINKC[B/N]	Airzone Think monochrome Thermostat wired 32Z [white/black]
④	AZDI6THINKR[B/N]	Airzone Think monochrome Thermostat wireless 32Z [white/black]
⑤	AZDI6MC[XXX]C	Airzone [Manufacturer] Individual Unit zone Module wired 32Z
⑥	AZDI6MZZONC	Airzone Actuator zone Module wired 32Z
⑦	AZDI6ZMO[XXX]R	Airzone [Manufacturer] Individual Unit zone Module wireless 32Z
⑧	AZDI6MCFRR	Airzone Infrared Individual Unit zone Module wireless 32Z
⑨	AZDI6OUTPUT8	Airzone Control Module of Radiant elements 32Z
⑩	AZX6WEBSLOUDC	Airzone X6 Cloud webserver ethernet

Operation logic Relay "radiant heating activation":

STADE / MODE	STOP	VENTILATION	COOL (AIR)	COLD (RADIANT)	HEAT (AIR)	HEAT (RADIANT)
DEMAND ON	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. ON	BOIL. OFF	BOIL. ON
DEMAND OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF

For further technical information click [here](#)

Note: These drawings provide a basis for the implementation of the project