


EQUIPO INVERTER DE CONDUCTOS ZONIFICADO PARA CONDUCTO FLEXIBLE
CON ELEMENTO RADIANTE HASTA 8Z



— Cable Bus Airzone
— Cable RN Airzone
⊜ Elemento con alimentación eléctrica independiente

①	AZEZ6[XXX][ST/SL/BS] [Gama] [Talla] [No. de puertas]	Easyzone Standard [marca] x 200 01 S3 Pasarela comunicaciones Airzone - [marca] Central de sistema Airzone Flexa 3.0- Innobus Pro6 -6 zonas
②	AZCE6BLUEFACEC[B/N]	Tto. cable a color Airzone Blueface 8Z [blanco/negro]
③	AZCE6LITER[B/N]	Tto. radio simplificado Airzone Lite 8Z [blanco/negro]
④	AZCE6OUTPUT8	Módulo de control elementos radiantes Airzone 8Z
⑤	PREJXXXXXT	Plenum aislado para rejilla
⑥	RDHVXXXXXBKX	Rejilla doble deflexión Airzone
⑦	AZX6WSC5GER	Webserver Airzone Cloud WiFi Dual 2.4-5G


Lógica Funcionamiento Relé "Caldera"_Sistema Centralizado:

ESTADO / MODO	STOP	VENTILACIÓN	FRÍO (AIRE)	FRÍO (RADIANTE)	CALOR (AIRE)	CALOR (RADIANTE)
DEMANDA ON	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. ON
DEMANDA OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF	CALD. OFF

Para mayor información técnica pulse [aquí](#)

Nota importante: Los presentes planos sirven de base para la realización del proyecto de ejecución

ZONED INVERTER UNIT FOR FLEXIBLE DUCT WITH RADIANT HEATING-UP TO 8Z



①	AZE6[XXX][ST/SL/BS] [Range][Size][No. of dampers]	[Manufacturer] Easyzon standard x 200 01 S3 Airzone -[Manufacturer] Communication gateway Airzone Innuobus Flexa 3.0 PRO 6 main control board 6z
②	AZCE6BLUEFACEC[B/N]	Airzone Blueface color Thermostat wired 8Z [white/black]
③	AZCE6LITER[B/N]	Airzone Lite Thermostat wireless 8Z [white/black]
④	AZCE6OUTPUT8	Airzone Control Module of Radiant elements 8Z
⑤	PREJXXXXXT	Insulated plenum for grille
⑥	RDHVXXXXXBKX	Airzone double deflection grille
⑦	AZX6WSC5GER	Airzone X6 Cloud webserver Wifi Dual 2.4-5G

Operation logic Relay "Boiler":

STATE / MODE	STOP	VENTILATION	COOL (AIR)	COOL (RADIANT)	HEAT (AIR)	HEAT (RADIANT)
DEMAND ON	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. ON
DEMAND OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF	BOIL. OFF

For further technical information click [here](#)

Note: These drawings provide a basis for the implementation of the project

TECHNICAL STUDY AIR CONDITIONING AIRZONE

PLAN WIRING DRAWINGS ZONED INVERTER UNIT FOR FLEXIBLE DUCT WITH RADIANT HEATING-UP TO 8Z

PLAN
1/1

SCALE
N/S

DEVELOPER
LOCATION
DATE
FILE

DIRECTOR Projects Department

Contact: projectsdepartment@airzone.es Phone: +34 900 400 445 www.airzone.es