




# ESQUEMA DE CONEXIÓN CCP CON EQUIPO AEROTERMIA DAIKIN ALTHERMA 3 - DOBLE CONSIGNA




**NOTA IMPORTANTE:** ES RESPONSABILIDAD DEL INSTALADOR VERIFICAR LA INFORMACIÓN SUMINISTRADA POR AIRZONE CON EL FABRICANTE DEL EQUIPO EN CUANTO A LA CONEXIÓN DE LA CCP (AZX6CCP) CON LA PRODUCCIÓN.



1	2	3	4	5	6	7	8	9	10	11	11a	12	13	14	14a	21	28	29	30	31	34a	35a	34	35

X2M

SW2  
2 TUBOS



Conexión necesaria para doble consigna

Esquema conexión

La producción se pone en marcha cuando establecemos el modo frío o caliente en el sistema Airzone.

Se cambia a la consigna adicional cuando tenemos demanda de aire.

Se tienen que definir la temperatura de la consigna principal (radiante) y de la adicional.

Para mayor información técnica sobre CCP pulse [aquí](#) Para configurar la doble consigna revisar los pasos del manual del fabricante.



ESTUDIO TÉCNICO CLIMATIZACIÓN AIRZONE  
PLANO ESQUEMA DE CONEXIÓN CCP CON EQUIPO AEROTERMIA DAIKIN ALTHERMA 3 - DOBLE CONSIGNA

ESCALA  
N/S  
PLANO  
1/1



PROMOTOR  
SITUACIÓN  
FECHA  
Nº EXP.

REALIZADOR Departamento de Proyectos Altra Corporación  
Contacto: gabinete.tecnico@airzone.es Teléfono: 900 400 445 www.airzone.es


# WIRING DIAGRAM CCP WITH AIR-WATER HEAT PUMP SYSTEM DAIKIN ALTHERMA 3 - DOUBLE SETPOINT



**IMPORTANT NOTE:** IT IS THE INSTALLER'S RESPONSIBILITY TO VERIFY THE INFORMATION SUPPLIED BY AIRZONE WITH THE EQUIPMENT MANUFACTURER REGARDING THE CONNECTION OF THE CCP (AZX6CCP) TO PRODUCTION.



SW2  
2 PIPES



Necessary connection for double setpoint

Wiring diagram

The production starts when we set the hot or cold mode in the Airzone system.

It switches to the additional setpoint when we have air demand.

Its necessary define the temperature of the main setpoint (radiant) and the additional setpoint.

For more information about CCP click [here](#) To configure the double setpoint check the steps of the manufacturer's manual.

TECHNICAL STUDY AIR CONDITIONING AIRZONE

PLAN WIRING DIAGRAM CCP WITH AIR-WATER HEAT PUMP SYSTEM DAIKIN ALTHERMA 3 - DOUBLE SETPOINT

PLAN 1/1  
ESCALA N/S

DEVELOPER  
LOCATION  
DATE  
FILE

DIRECTOR Departamento de Proyectos Altra Corporación  
Contact: gabinete tecnico@airzone.es Teléfono: 900 400 445 www.airzone.es

AIRZONE